



RETAINING "CINCH" PLATE



DO NOT PLACE PLATES IN GROOVE



GENERAL INSTALLATION

IN 1 AND 2 HR RATED MASONRY FLOORS AND CEILINGS OR WALLS




FIGURE 2

- ITEM DESCRIPTION
1. F0R25 ROUND FIRE DAMPER
  2. RETAINING PLATE, 20 GA. STEEL
  3. DUCT
  4. MASONRY WALL CONSTRUCTION
  5. #10 CONCRETE ANCHOR
  6. DRAW BAND




FIGURE 1

WITHIN SQUARE OPENING IN METAL OR WOOD STUD FRAMING IN 1 AND 2 HR RATED DRYWALL PARTITIONS

BLADE ORIENTATION





FIGURE 4

- ITEM DESCRIPTION
1. F0R25 ROUND FIRE DAMPER
  2. RETAINING PLATE, 20 GA. STEEL
  3. DUCT
  4. METAL STUD WALL CONSTRUCTION
  5. #10 STEEL METAL SCREW
  7. DRAIN BAND




FIGURE 3