

3900 Dr. Greaves Rd.

Kansas City, MO 64030

(816) 761-7476

•

FAX (816) 765-8955

INSTALLATION DETAILS ELF375DXD LOUVER MIAMI-DADE COUNTY & FLORIDA PRODUCT APPROVED

•



Dimensions in inches, parenthesis () indicate millimeters.

ELF375DXD LOUVER INSTALLATION DETAIL

Refer to back page for Table 1 and other details

NOTES:

- 1. The installation shown herein must be followed strictly to ensure compliance with Miami-Dade and Florida Approvals.
- 2. Aluminum clip angles and #10 screws shown above are provided by Ruskin. Anchors for connection to structure are not provided by Ruskin.
- 3. One anchor into the substrate is required at every clip angle. Reference Table 1 for anchor information.
- 4. Ruskin is not responsible for determining the suitability of the structure, or for gaining approval for non-compliant installations.
- 5. Shims may be required to achieve consistent clearance between louver and opening on all sides. Shims are not provided by Ruskin.
- 6. Backer rod and sealant are not provided by Ruskin.
- 7. HVBS = Hidden Vertical Blade Support.
- 8. NIRC = Not in Ruskin's Contract.



STRUCTURE	ANCHOR (By Others)	INSTRUCTIONS
Wood	⁵ /16" (8) Dia. Lag Bolt	3" (76) embed, 41/2" (115) min. edge
Concrete 3000 Min. PSI	^{5/16"} (8) Dia. Tapcon (ITW or equal)	21/2" (64) embed, 5" (127) min. edge
Concrete 2000 Min. PSI	⁵ /16" (8) Dia. Expansion Anchor (Hilti or equal)	13/4" (44) embed, 4" (102) min. edge
Grout Filled Block	^{5/16"} (8) Dia. Tapcon (ITW or equal)	13/4" (44) embed, 4" (102) min. edge
Steel Framing (12 Ga. Min.)	5/16" (8) Dia. A307 Bolt or Self-Tapping Screw	1.5 x fastener dia. min. edge

NOTES:

1. All fasteners must be installed per the manufacturer's Miami-Dade/Florida approved installation instructions.

2. Dimensions in inches, parenthesis () indicate millimeters.



3900 Dr. Greaves Rd. Kansas City, MO 64030 (816) 761-7476 FAX (816) 765-8955 www.ruskin.com