

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3235-0245:0121
CATEGORY: 3235 -- COMBINATION FIRE/SMOKE DAMPERS

LISTEE: RUSKIN3900 Dr. Greaves Road, Kansas City, MO 64030
 Contact: Josiah Wiley (816) 761-7476 Fax (816) 966-1654
 Email: jwiley@ruskin.com

DESIGN: Model FSD60C
 Refer to listee's data sheet and UL Fire Resistance Directory for additional detailed product description and operational considerations.

<u>Model</u>	<u>Hour</u>	<u>Leakage Class</u>	<u>Position</u>	<u>Single. in.</u>		<u>Multiple. in.</u>			
				W	H	W	H		
				Min.	Max.	Min.	Max.		
FSD60C	1-1/2	I-350	H,V	12	24	6	24	NA	NA
FSD60C	1	I-350	H	12	24	6	24	NA	NA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type identification, and UL label.

APPROVAL: Listed as a 1-1/2 hr. Combination Fire/Smoke Damper and 1 hr. Corridor Damper.

7-1-11 MT



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division